


David de Diego Villarrubia
Chief Infrastructure & Facilities Officer
Kumo networks S.A.U
C. Santiago Navarro, 8
Murcia 30100
Spain



15 October 2014

Tier IV Certification of Design Documents for Kumo networks S.A.U – Kumo/Murcia Data Center in Murcia, Spain

Dear David de Diego Villarrubia,

Uptime Institute Professional Services is pleased to revise the Tier Certification of Design Documents for the Kumo networks S.A.U – Kumo/Murcia Data Center as fulfilling Tier IV Fault Tolerant criteria. This Certification is based upon the design documentation submitted between 28 March and 14 October 2014.

This Certification supersedes the Tier IV Certification of Design Documents for KIO Networks España S.A. – KIO/Murcia Data Center with 15 October 2016 expiry.

This Certification recognizes that Kumo networks S.A.U – Kumo/Murcia Data Center is capable of supporting any planned work or unplanned event on the site infrastructure without disrupting more than the redundant computer room power and cooling capacity. This Tier IV Certification is limited by the stated total peak IT load of 528 kilowatts (kW). This includes 468 kW for the Sala IT data hall, 30 kW for the Sala MPOE-1 y MDA-1 room, and 30 kW for the Sala MPOE-2 y MDA-2 room.

Tier IV criteria are founded on the capability to detect and isolate a fault within a facility's critical systems while sustaining the critical load and *without an impact to the delivery of power and cooling to the critical areas*. Although the systems are designed with Fault Tolerant criteria, certain operations-related errors, such as inadvertent activation of equipment-level EPO features, or malicious intervention, may still impact critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

The Tier IV Certification of Design Documents award is valid until 15 October 2016, subject to the limitations and extension request process set forth in the attached Schedule I.

Congratulations on this achievement.

Sincerely,



Christopher Brown
Chief Technical Officer