

David de Diego Villarrubia
CIFO - Chief Infrastructure & Facilities Officer
Kumo networks S.A.U
Carrer Corretger n° 31 Paterna
Valencia 46988
Spain



3 December 2025

Tier IV Certification of Design Documents for Kumo networks S.A.U – CAMPUS DATA CENTER SEDE Valencia, FASE I in Valencia, Spain

Dear David de Diego Villarrubia,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Design Documents for the Kumo networks S.A.U – CAMPUS DATA CENTER SEDE Valencia – Fase I as fulfilling Tier IV Fault Tolerant criteria. This Certification is based upon the design documentation submitted between 9 August 2023 and 5 November 2025.

This Certification recognizes that Kumo networks S.A.U – CAMPUS DATA CENTER SEDE Valencia, Fase I is capable of supporting any planned work or unplanned event on the site infrastructure without disrupting more than the redundant computer room power and cooling capacity. This Tier IV Certification is limited by the stated total peak IT load of 954 kilowatts (kW). This includes 306 kW in Sala EDA; 12 kW in Sala ZDA-A; 12 kW in ZDA-B; 14 kW in Sala MDA-A; 14 kW in Sala MDA-B; 44 kW in each of mutually redundant Sala ER-A and Sala ER-B; 256 kW in Sala DIMM-1; 256 kW in Sala DIMM-2; 20 kW in Sala ZDA-C; and 20 kW in Sala ZDA-D.

Tier IV criteria are founded on the capability to detect and isolate a fault within a facility's critical systems while sustaining the critical load and without an impact to the delivery of power and cooling to the critical areas. Although the systems are designed with Fault Tolerant criteria, certain operations-related errors, such as inadvertent activation of equipment-level EPO features, or malicious intervention, may still impact critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

The Tier IV Certification of Design Documents award is valid until 3 December 2027, subject to the limitations and extension request process set forth in the attached Schedule I.

Congratulations on this achievement.

Sincerely,



Christopher Brown
Chief Technical Officer