

David de Diego Villarrubia
Chief Infrastructure & Facilities Officer
Kumo networks S.A.U
C. Santiago Navarro, 8
Murcia 30100
Spain



21 November 2014

Tier IV Certification of Constructed Facility for Kumo networks S.A.U – Kumo/Murcia Data Center in Murcia, Spain

Dear David de Diego Villarrubia,

Uptime Institute Professional Services is pleased to revise the Tier Certification of Constructed Facility for the Kumo networks S.A.U – Kumo/Murcia Data Center as fulfilling Tier IV Fault Tolerant criteria. The Tier Certification is based on the design, facility demonstrations, and the on-site verification of the constructed facility completed 30 October 2014.

This Certification supersedes the Tier IV Certification of Constructed Facility for KIO Networks España S.A. – KIO/Murcia Data Center dated 21 November 2014.

This Certification recognizes that Kumo networks S.A.U – Kumo/Murcia Data Center is capable of supporting any planned work or unplanned event on the site infrastructure without disrupting more than the redundant computer room power and cooling capacity. This Tier IV Certification is limited by the as-demonstrated total peak IT load of 528 kilowatts (kW). This includes 468 kW for the Sala IT data hall, 30 kW for the Sala MPOE-1 y MDA-1 room, and 30 kW for the Sala MPOE-2 y MDA-2 room.

Tier IV Fault Tolerant criteria are founded on the capability to detect and isolate a fault within a facility's critical systems while sustaining the critical load and *without an impact to the delivery of power and cooling to the critical areas*. Although the systems are designed with Fault Tolerant criteria, certain operations-related errors, such as inadvertent activation of system-level EPO features, or malicious intervention, may still impact critical load.

This Tier Certification is valid until the facility is modified, including any changes to the capacity components or distribution paths depicted in the design identified above, and submitted for review. This Certification is subject to the limitations set forth in Schedule I hereto and incorporated herein.

This Tier IV Certification of Constructed Facility represents Kumo networks S.A.U's continued investment and commitment to site uptime availability.

Congratulations on this significant achievement.

Sincerely,



Christopher Brown
Chief Technical Officer